

## FIRE – CLASS “C”

**SIZE IT UP**  
Casualty initial reports, assessment,  
evaluation and information.  
What do I have

ORDERED	EXECUTED	C Time	
		Reported = (Size It Up) <i>Report Casualty Steps</i>	
		1. Report Class C Fire.	
		2. Rapid response on scene.	
		3. Establish communications, take initial actions, report.	
		4. Fire in one compartment or _____ compartments.	
		5. Compartment name, number, space access, if fire is accessible.	
		6. Location within the space (chit).	
		7. Size, cause of fire if known, (flooding, water leak, overload, unknown).	
		8. Source of fire (ABT, breaker box, fuse panel, motor, motor controller, 110 volts, 220 volts, 440 volts, 2160 volts).	
		9. System affected (lighting, vital, non-vital, weapon, engineering).	
		10. Immediate material resources available (CO2 hose reel, fresh water hose reel), activate as required.	
		11. Immediate personnel resources available (flying squad, repair parties, duty section, off ship services), request as required.	
		12. Determine additional hazards (fumes, smoke).	
		13. Determine personnel casualties and evacuate the area.	
		14. Report and size up casualty area.	
		15. Move to <i>Engage Casualty Phase</i> .	

## CASUALTY CHECK-LIST

**FIGHT IT**  
Casualty engagement  
What am I doing to  
make progress

ORDERED	EXECUTED	C Time	
		Engaged = (Fight It) <i>Engage Casualty Steps</i>	
		1. Engage Class C Fire.	
		2. Secure power if permitted.	
		3. Determine attack method.	
		4. Determine type of extinguishing agent (CO2, water, fresh water, PKP, installed systems, none required).	
		5. Team brief of assessment, tactic, access method, route, PPE, risk; establish and check communications.	
		6. Equipment selected, laid out and checked; relief's standing by.	
		7. Team execution, air on if required, communication check, test agent.	
		8. Access space or system, apply attack method, attack fire.	
		9. Evaluate attack method, continue or adjust, assess risk.	
		10. Rotate firefighters, rotate in relief's if required.	
		11. Report when attack method takes effect, re-evaluate situation, re-apply agent.	
		12. Move to <i>No Casualty Phase</i> .	

## FCC-111306

**MONITOR IT**  
The fight is complete,  
No further spread, Clean it up

ORDERED	EXECUTED	<del>C</del> Time	
		No = (Monitor It) <i>No Casualty Steps</i>	
		1. No Class C Fire (Fire Out).	
		2. Report when FF extinguishes main fire (fires out).	
		3. Set reflash watch.	
		4. Investigate for hidden fire.	
		5. Overhaul as required and investigate space.	
		6. Commence desmoking.	
		7. Conduct post fire atmospheric testing.	
		8. Conduct de-watering (if required).	
		9. Conduct visual of damaged area, hidden and secondary damage.	
		10. Conduct damage assessment, photos, report.	
		11. Debrief team.	